

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245640
Address: 4420 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Thursday, August 07, 2025

Corrective Action Required:

1	Miscellaneous Correction	-the bottom section of handrail to basement needs to comply to section R311.7.8-R311.7.8.4 of the 2018 IRC It needs to be continuous from top to bottom of stairs and 34"-38" in height
---	--------------------------	--

Comments: