

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246348
Address: 211 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, August 07, 2025

Corrective Action Required:

1	Misc	-Provide accessible entrance (plan shows ada compliant ramp) -Provide accessible door hardware (knob style not permitted) -Provide anti siphon device at hose bib -Complete corrections for LSFD
---	------	---

Comments: