

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250347
Address: 1055 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Partial	Friday, August 08, 2025

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. - TRIM TALL VEGETATION ON LOT - PROTECT FRONT OF LOT
---	---------------------------------------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	07/30/25 Jamie S, Erosion control needs to be reestablished. Street needs to be cleaned. Construction debris needs to be removed from lot. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 08/04/25 Jamie S, Erosion Control has been reestablished.
---	----------------------------	---

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	8/6/25 Tyler S. SW, curb, and street need debris and dirt cleaned up. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS 8-8-25 Dustin A, SW has been cleaned , laying sod today
---	----------------------------	---

Comments: