



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20252591, Public Works Right of Way Permit
Address: 414 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Passed	Friday, August 08, 2025

Corrective Action Required

1	Misc	They turned in the concrete tickets. Passed.
---	------	--

Comments: