



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120225, Building Permit - Commercial
Address: 635 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Tuesday, March 13, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY UNDER-SLAB PVC DWV PIPING
EXCEPT F.D. @ MECH RM NOT YET INSTALLED.

Comments: