

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20246440
Address: 2769 SW 12TH ST, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Jamie Simerly	Failed - Stop Work	Friday, August 08, 2025

Corrective Action Required

1 Miscellaneous Correction - PROTECT FRONT OF LOT
- TRIM ALL TALL VEGETATION

Corrective Action Required

2 DCM3 ESC REQUIRED 2 DAY
08/05/25 Jamie S, Silt is escaping from under the sod and covering the sidewalk and street causing a safety hazard for residence around mailbox. Erosion control measures and cleanup of public surfaces are required until vegetation is established enough to stop silt for escaping on to public surfaces.
EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
08/08/25 Jamie S, Silt is still present on sidewalk and the around mailbox. No erosion control has been placed to prevent it.

Comments:

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201