

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20252298  
**Address:** 2766 SW 12TH ST, LEES SUMMIT, MO 64081

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Jamie Simerly	Failed - Stop Work	Friday, August 08, 2025

**Corrective Action Required**

1	DCM6 ESC INSP DENIED STREET CLEAN UP	REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED.
---	---	--

- More gravel needed on construction entrance

**Corrective Action Required**

2	DCM3 ESC REQUIRED 2 DAY	08/05/25 Jamie S, Erosion control on the back of the lot needs to be addressed around the storm drain east of the property. Strom drain must be cleaned out and silt fence reestablished. Spoils and construction debris on the back of the lot need to be contained as well. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 08/08/25 Jamie S, Erosion control has not been addressed for the back of the lot around storm drain or spoils.
---	----------------------------	---

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

**Comments:**