

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251357  
Address: 2132 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Drew Fischer	Failed	Friday, August 08, 2025

Corrective Action Required:

2	Misc	2132 SW Wheatfield dr
		- Security blocking at back door
		- Add straps at top plate at hvac penetrations
		- Fire blocking needed top of dryer vent

**Comments:**