CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251423

Address: 616 SE LINDBERG LN, LEES SUMMIT, MO 64063618 SE LINDBERG LN, LEES SUMMIT, MO 64063620

SE LINDBERG LN, LEES SUMMIT, MO 64063614 SE LINDBERG LN, LEES SUMMIT, MO

64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Mitchell Schwarz Not Ready Monday, August 11,

Commercial 2025

illinercial 202

Informational:

1 Misc -perimeter footing inspection completed

Corrective Action Required:

2 Misc Stem wall not formed

Comments: