

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250029
Address: 667 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Partial	Tuesday, August 12, 2025

Informational:	
1 Misc	Partial inspection only -Exterior nailing inspection for portal framing at garage and front porch. Okay to cover -trusses at front porch okay to cover -truss hold downs above hvac room okay

Comments: