

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Failed	Tuesday, August 12, 2025

Corrective Action Required:

1	Misc	BOTH -label all disconnects and panels -provide listing for ground connections where using dissimilar metals Left panel -land all grounds together (self tapping screws not permitted to connect lugs to panel)
---	------	---

Comments: