

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Devon Perry	Passed	Tuesday, August 12, 2025

Informational:

1	Misc	10-29-24 DP. Met Floyd onsite and took sample 3 from the 6" fire hydrant line, sample 1 from the domestic service line and the fire line to the building pad.
		10-30-24 DP. The 3rd sample from 3 from the 6" fire hydrant line, sample 1 from the domestic service line and the fire line to the building pad all PASSED

Comments: