

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Construction Inspection</b>	Devon Perry	Passed	Tuesday, August 12, 2025

Informational:

1 Misc

10-15-24 DP. Floyds crew got the line to the fire hydrant up to 200 psi. It stayed at 200 psi for 2 hours.

10-16-24 DP. Floyds crew got the fire line chlorinated at 10AM today.

**Comments:**