

Scott Ready

From: Ishita Banerjii <ibanerjii@DLRGROUP.com>
Sent: Tuesday, August 12, 2025 10:50 PM
To: Scott Ready
Cc: Lindsay Murray
Subject: TOC signage
Attachments: 2025 0812 MCC LV AUTO_TCO mark up.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

CAUTION! This is an **EXTERNAL** email originated from outside the organization. Do not click links or open attachments unless you recognize the **SENDER** and know the content is safe.

Good evening Scott,

As discussed on site, I am following up to confirm that the college has agreed to a maximum occupant load of **49 persons for Level 2 of Area B** during the Phase 3 Construction.

Please confirm that this temporary occupant load is acceptable from your end. Attached is the phasing plan with the Level 2 marked up in gray hatch confirming that the max occupant load will be limited to 49.

Thank you, and please let me know if any additional information or documentation is required.

Best regards,

Ishita Banerjii, AIA, LEED AP

(she/her/hers)

Project Manager | Senior Associate

ibanerjii@dlrgroup.com

DLR Group

o: 913-897-7811 | m: 913-314-8855

[Annual Appointments Celebrate New Leaders](#)