

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243864
Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Shawn Hoffman	Partial	Wednesday, August 13, 2025

Corrective Action Required:

2	Misc	- HVAC constricted at Y in business area - above ceiling plumbing ok and ready for insulation - Electrical not ready
---	------	--

Comments: