

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250724
Address: 2829 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Wednesday, August 13, 2025

Informational:

1	Misc	Portal frame at garage ok Front and back porch ceiling ok to cover
---	------	---

Corrective Action Required:

2	Misc	2829 SW Heartland Rd - Add 2 2x4 under LVL in owners closet - Add king stud to doorway owners suite to owners bathroom - Add king stud to each side of window in owners suite -
---	------	---

Comments: