

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250160
Address: 2623 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Failed	Wednesday, August 13, 2025

Informational:

1 Misc

07/24/25 Jamie S, DW is formed and compacted. Approved to pour.
07/30/25 Jamie S, DW still has forms up. Forms need to be pulled before inspection. Call in for reinspection once forms are pulled.
8/13/25 Tyler S. Driveway does not meet cross slope standards and is over 2.1% in multiple areas. Driveway will need to be fixed to comply with ADA standards. Please call in for another inspection.

Comments: