

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250844
Address: 2611 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Failed	Wednesday, August 13, 2025

Informational:

1	Misc	8/6/25 Tyler S. DW is formed and compacted to city spec. Approved to pour. 8/13/25 Tyler S. DW is not in compliance with ADA standards. Cross slope is more the 2.1% in multiple area. Inspection failed. Will need to tear out and replace. Please call in for another pre-inspection when ready.
---	------	---

Comments: