

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251365
Address: 1047 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Tyler Schreck	Passed	Thursday, August 14, 2025

Informational:
1 Misc 8/7/25 Tyler S. DW is formed and compacted to city specs. approved to pour.
8-14-25 Tyler S. Driveway is in compliance with ADA specs. Passed.

Comments: