

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mitchell Schwarz	Partial	Thursday, August 14, 2025

Informational:

1 Misc

Underground electrical-OK below:

-ue from outside building 4 to trash center, carport, light pole, and between
garage 4B&C

-cont. to carport, sign monuments, and garages south of main site entra

--ground rod and connection to light poles 3 most W light poles infront of club
house

Comments: