

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246286

Address: 1338 SW WINTHROP TER, LEES SUMMIT, MO 640811336 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Thursday, August 14, 2025

Corrective Action Required:

1	Misc	1336 SW Winthrop - fire blocking needed at top of wall to right of post in wall of bed 3/ bed 3 closet - Fire blocking needed at top of wall transition at end of basement hallway to ceiling in bedroom 3 closet - Fire blocking needed at north end of soffit face to wall transition in basement bedroom 4 - 3rd stud required under LVL at entryway/BA 2 wall -
---	------	--

Comments: