

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20252640  
Address: 1500 NE PARK SPRINGS TER, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Khanh Nguyen	Failed	Monday, August 18, 2025

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	Provide adequate erosion control along the street on the west side of lot.  No further inspection if erosion control is not in compliance
---	---------------------------------------	---

**Comments:**