

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253133
Address: 4716 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Passed	Monday, August 18, 2025

Informational:
1 Misc Pool components bonded:
-Pool shell, perimeter bonding, ladder, handrail, pool cover rails, jumper to pool cover and pool equipment location

Comments: