

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250075
Address: 628 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, August 19, 2025

Corrective Action Required:

1 Misc

- main disconnect breaker not setting correctly due to tension from feeder cable
- bonding screw for all metallic boxes to be compliant with 250.126 of NEC
- protect all wires within 6' of attic
- address exterior wall studs over board for dwv in primary bath (missing nailes in stud shoe)
- truss plans do not match garage trusses doubled
-

Comments: