

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250106
Address: 1817 NE LASHBROOK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Khanh Nguyen	Partial	Tuesday, August 19, 2025

Corrective Action Required:

1	DCM5 ESC INSP DENIED	Erosion control is in compliance
---	-------------------------	----------------------------------

Comments: