

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20245409
Address: 1616 SW BUCKTHORN ST, LEES SUMMIT, MO 64082
Inspected On: Tuesday, August 19, 2025
Inspected By: Development Center
Expiration Date: 9/18/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Thursday, April 24, 2025

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -install gutters -land sewer tracer wire in box -address deck post to beam connection deck post over notched. Provide approved deck post to be connector
---	------	--

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Tuesday, March 25, 2025
---	------------------	-------------------	-------------------------

Corrective Action Required:

2	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -install gutters -land sewer tracer wire in box -address deck post to beam connection deck post over notched. Provide approved deck post to be connector
---	------	--

Comments: