

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244115
Address: 1530 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Wednesday, August 20, 2025

Informational:
1 Misc 2-6-25 Dustin A, SW formed and compacted. Slopes are in compliance.
Approved to pour
2-13-25 Jamie S, SW is covered in snow, cannot inspect until it is cleared.
8-20-25 Dustin A. sw is poured to city specs

Comments: