

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250633
Address: 410C SE 3RD ST, Unit:107, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Wednesday, August 20, 2025

Corrective Action Required:

1	Misc	-All electrical in patient care rooms to comply with NEC 517.13 -NM cables not permitted above acoustic ceilings
---	------	---

Comments: