



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114943, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Friday, March 16, 2012

Partial Correction
1 MISC

LIGHT GAUGE STEEL FRAMING AT EXTERIOR WALL AT LOCATIONS:

1ST LEVEL: (11) FROM (B) TO (F); (DD) FROM (0.3) TO (2.5) FULL HEIGHT; B/11 TO B/0.2 TO BB/0.2; CC.4/0.2 TO DD/0.2;

2ND LEVEL: (DD) FROM (0.3) TO (7.2) FULL HEIGHT; B/11 TO B/0.2 TO DD/0.2;

3RD LEVEL: PARAPET WALL SW CORNER TO COMPLETE THIS LEVEL

Comments: