

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250248
Address: 2758 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, August 21, 2025

Corrective Action Required:

- | | |
|---|------|
| 1 | Misc |
| - Provide 3' splash pads at down spouts | |
| - Sump discharge to be 36" away from foundation | |
| - land water valve to grade | |

Comments: