



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20114738
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Friday, March 16, 2012
Inspected By: John Borns
Expiration Date: 3/29/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|------------------|------------------------|
| Occupancy Inspection - Codes Commercial | John Borns | Temporary C of O | Friday, March 16, 2012 |

Corrective Action Required:

1 MISC HOOK-UP OF SINKS AT KITCHEN TO BE COMPLETED.

Corrective Action Required:

2 MISC GRAB BARS AND MIRRORS TO BE INSTALLED AT
RESTROOMS

Corrective Action Required:

3 MISC EXPOSED GAS PIPE TO BE PAINTED FOR CORROSION
PROTECTION

**Comments: ANSI-REQUIRED GRAB BARS TO BE INSTALLED BEFORE PUBLIC
AND RESIDENTS OCCUPY FACILITY.**