

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252490
Address: 910 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Thursday, August 21, 2025

Corrective Action Required:

1	Misc	-Remove drywall at mechanical room -Install THWN conductors at underslab electrical -Bed new dwv in gravel -Protect all inwall dwv **ok to hang furout wall
---	------	---

Comments: