

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250027
Address: 651 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Partial	Thursday, August 21, 2025

Corrective Action Required:

1	Misc	-Portal frame inspection on front window and rear garage nailing okay -hold downs for trusses above hvac room okay to cover -front sheathing nailing okay to cover
---	------	--

Comments: