

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, August 21, 2025

Corrective Action Required:

1	Misc	-At north service disconnect, connect water and ufer grounding electrode conductors to a grounding bus bar. Install a 3/0 CU or 250 AL bonding jumper from this bus bar to the service grounded bus bar -Protect GECs of both disconnects inside PVC
---	------	---

Comments: