

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20120225	Date:	March 19, 2012
Project Title:	EMALINE BALL ROOM	Applicant:	
Location:	635 SW 2ND ST. LEES SUMMIT, MO 64063		NORTHWEST MISSOURI AUTOMATIC SPRINKLER CORP SE 7401 HIGHWAY 69 LAWSON, MO 64062 (816) 792-0359
Type of Work:	Sprinkler Alteration		
Occupancy Group:	A-2		
Description:	FINISH SPACE FOR BANQUET FACILITY		
Construction Type:	Type VB (Unprotected)		
Map Page:	195F		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. Plans released per plan revisions and letter from H.D. Doshi P.E. dated March 14, 2012.
2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
3. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing system shall have documentation of a current annual inspection. Verified at inspection.