

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245048
Address: 2739 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Friday, August 22, 2025

Corrective Action Required:

1	Misc	8/21/25 Tyler S. DW is out of compliance and does not meet ADA specs. DW is over 36 ft. wide and cross slope is over 1.5%. Talked to Colby and he is aware of this.
---	------	---

Comments: