

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245048  
Address: 2739 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                   |
|----------------------------|----------------|----------|-------------------------|
| <b>Sidewalk Inspection</b> | Dustin Agcopra | Failed   | Friday, August 22, 2025 |

Informational:  
1 Misc 07/09/25 Jamie S, SW is compacted, formed and slopes are in compliance with city standards. Approved to pour.  
8/21/25 Tyler S. SW was cut out for DW expansion. SW pre pour is out of compliance due to no compaction.

**Comments:**