

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250075  
Address: 628 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, August 22, 2025

**Corrective Action Required:**

1	Misc	-main disconnect breaker not setting correctly due to tension from feeder cable -bonding screw for all metallic boxes to be compliant with 250.126 of NEC -uncover covered from porch for viewing hold downs -no more than 2 NM through top plate penetrations check throughout -ufer ground connection to remain accessible
---	------	--

**Comments:**