

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251357
Address: 2132 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Friday, August 22, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	8/21/25 Tyler S. Silt fence is down in multiple areas and gravel and debris needs swept off of the road and curb line. The porta-potty need to be moved and cannot be on public roadways. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. Corrections need to be done by the 27th or a stop work order will be issued.
---	----------------------------	---

Comments: