

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244252
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Khanh Nguyen	Partial	Friday, August 22, 2025

Corrective Action Required:

1	Misc	Pool components bonded: -6 light niches, pool shell, handrails bases, pool water at skimmer, bonding jumper to pool equipments room, perimeter bonding jumpers, spa bonding
---	------	--

Comments: