

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Partial	Friday, August 22, 2025

Corrective Action Required:

1	Misc	(4) interior footings from north end south 60' to first step down -South perimeter footing approved per 3rd party report - Office building North, - Copper UFER in place office building on East end (3) Piers for west canopy
---	------	--

Comments: