

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20252013  
Address: 2618 SW FIREFLY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Drew Fischer	Failed	Friday, August 22, 2025

Corrective Action Required:

1	Misc	2618 SW Firefly Ln - Fire blocking needed at end of beam in stairway landing - Fire blocking holes in top plate in closet of front bedroom, along front wall of house - Fire blocking around plumbing above window on north end of basement living room - Fire blocking above windows in both basement bedrooms -
---	------	--

Comments: