

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251620
Address: 2717 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, August 25, 2025

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | - Protect water lines in master bedroom/ shower with boca plates not strike plate |
| | | - Nail off floor joists that are cut between basement stairs and garage wall |

Comments: