

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241493
Address: 2120 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Monday, August 25, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Monday, August 25, 2025

Corrective Action Required:

1	Miscellaneous Correction	-fencing needed around the pool -sidewalk needs inspection -splash blocks needed or tie into drain tile -sod needed -as graded plot plan needed -driveway inspection needed
---	-----------------------------	--

Comments: