

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250106
Address: 1817 NE LASHBROOK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, August 27, 2025

Corrective Action Required:

1	Misc	-Nail siding to sill plates and stud along edge @ 6" oc **Nail along vertical edge of siding panel to studs @6" oc, not 8" or 12"
		-Brace roof beams against rotation **Brace the (2)2x12 roof beam above the master closet

**OK TO INSULATE

Comments: