

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250045
Address: 644 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, August 27, 2025

Corrective Action Required:

1	Misc	Partial inspection only Garage portal frame okay to cover.
---	------	---

Corrective Action Required:

2	Misc	- Engineered changes to portal frames on the back of house. EC1 and EC2 in place but not tightened down
---	------	---

Comments: