

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235681
Address: 3200 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Friday, August 22, 2025

Informational:

1	Misc	-walls and ceiling screw pattern OK for units 301-307
---	------	-------------------------------------------------------

Corrective Action Required:

2	Misc	Elevator fire barrier wall screw pattern not inspected. Protect all membrane penetrations
---	------	-------------------------------------------------------------------------------------------

Comments: