

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

**Inspection Summary**

Permit #: PRCOM20235681  
Address: 3200 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Failed	Wednesday, August 27, 2025

Informational:

1 Misc

Elevator fire barrier:

-inner side wall screw pattern OK

-attic side OK

-walls and ceiling screw pattern OK for units 301-307

Corrective Action Required:

2 Misc

**\*\*Protect all fire barrier gap and penetrations**

**Comments:**