

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	John Jackson	Passed	Wednesday, August 27, 2025

Informational:
1 Misc 08/27/25 Wednesday (Gen. Level, Sub. Burnaugh Construction)
Hydrostatic test passed 2hr test @ 200psi around 1:30PM.

Comments: