

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Drew Fischer	Partial	Wednesday, August 27, 2025

Informational:

1 Misc

Conduit trench ok to fill across lot tying buildings 3,4,5 to 1&2
Conduit trench ok to fill that connects service between buildings 3&4
Conduit ok to cover that feeds between light poles in front of building 2;
conduits to 6 light poles at south&west side of building 1 and conduits to 2
light poles at east side of building 2
: 2" conduit connecting north end of building 4 to east end of building 5
: 1 1/2" conduit from building 4 to light poles between buildings 4&5

Comments: